

ANNUAL  
WATER  
QUALITY  
REPORT

WATER TESTING PERFORMED IN 2015

*Presented By*

**LaGRANGE** *georgia*  
S M A R T M O V E <sup>SM</sup>


PWS ID#: 2850001

## To Our Customers

We at the City of LaGrange Public Utilities Department are pleased to present you with this annual Drinking Water Quality Report for 2015. The U.S. Environmental Protection Agency and Georgia Department of Natural Resources require that all water providers produce an annual report informing customers about the quality of their drinking water. This report includes details about where your tap water comes from, what it contains, and how test results compare with safe drinking water standards. In 2015, as in years past, our water system was in compliance with all state and federal drinking water regulations.

## Important Health Information

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants may be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. The U.S. EPA/CDC (Centers for Disease Control and Prevention) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline at (800) 426-4791 or <http://water.epa.gov/drink/hotline>.



## Source Water Assessment

A source water assessment has been conducted on the City of LaGrange watershed as required by the Safe Drinking Water Act. The purpose of the assessment is to identify potential sources of contamination and the possible risk that is imposed on our water supply. Our overall susceptibility to source water contamination was determined through this analysis to be “low.” A copy of the report can be obtained from the City upon request.

## Substances That Could Be in Water

To ensure that tap water is safe to drink, the U.S. EPA prescribes regulations limiting the amount of certain contaminants in water provided by public water systems. U.S. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of these contaminants does not necessarily indicate that the water poses a health risk.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals, in some cases, radioactive material, and substances resulting from the presence of animals or from human activity. Substances that may be present in source water include:

**Microbial Contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, or wildlife;

**Inorganic Contaminants**, such as salts and metals, which can be naturally occurring or may result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming;

**Pesticides and Herbicides**, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses;

**Organic Chemical Contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production and may also come from gas stations, urban stormwater runoff, and septic systems;

**Radioactive Contaminants**, which can be naturally occurring or may be the result of oil and gas production and mining activities.

For more information about contaminants and potential health effects, call the U.S. EPA's Safe Drinking Water Hotline at (800) 426-4791.

## Lead in Home Plumbing

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high-quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at [www.epa.gov/lead](http://www.epa.gov/lead).

## Where Does My Drinking Water Come From?

The City of LaGrange withdraws water from the abundant resources of the Chattahoochee River and West Point Lake Reservoir. There are sufficient quantities of water in this basin to supply our community's needs well into the future. Our advanced treatment process ensures that source water is thoroughly disinfected, purified, and filtered before delivery to customers. However, we do experience occasional taste and odor problems during late summer and early fall associated with algae growth in the lake.

## Tap vs. Bottled

Thanks in part to aggressive marketing, the bottled water industry has successfully convinced us all that water purchased in bottles is a healthier alternative to tap water. However, according to a four-year study conducted by the Natural Resources Defense Council, bottled water is not necessarily cleaner or safer than most tap water. In fact, about 25 percent of bottled water is actually just bottled tap water (40 percent according to government estimates).

The Food and Drug Administration is responsible for regulating bottled water, but these rules allow for less rigorous testing and purity standards than those required by the U.S. EPA for community tap water. For instance, the high mineral content of some bottled waters makes them unsuitable for babies and young children. Further, the FDA completely exempts bottled water that's packaged and sold within the same state, which accounts for about 70 percent of all bottled water sold in the United States.


People spend 10,000 times more per gallon for bottled water than they typically do for tap water. If you get your recommended eight glasses a day from bottled water, you could spend up to \$1,400 annually. The same amount of tap water would cost about 49 cents. Even if you installed a filter device on your tap, your annual expenditure would be far less than what you'd pay for bottled water.

For a detailed discussion on the NRDC study results, check out their Web site at [www.nrdc.org/water/drinking/bw/exesum.asp](http://www.nrdc.org/water/drinking/bw/exesum.asp).

## Water Main Flushing

Distribution mains (pipes) convey water to homes, businesses, and hydrants in your neighborhood. The water entering distribution mains is of very high quality; however, harmless sediment can build up in areas of the distribution mains over time. Water main flushing is the process of cleaning the interior of water distribution mains by sending a rapid flow of water through the mains.

Flushing maintains water quality in several ways. For example, flushing removes sediments like iron and manganese. Although iron and manganese do not pose health concerns, they can affect the taste, clarity, and color of the water. Additionally, sediments can shield microorganisms from the disinfecting power of chlorine, contributing to the growth of microorganisms within distribution mains. Flushing helps remove stale water and ensures the presence of fresh water with sufficient dissolved oxygen, disinfectant levels, and an acceptable taste and smell.



During flushing operations in your neighborhood, some short-term deterioration of water quality, though uncommon, is possible. You should avoid tap water for household uses at that time. If you do use the tap, allow your cold water to run for a few minutes at full velocity before use and avoid using hot water, to prevent sediment accumulation in your hot water tank.

Please contact us if you have any questions or if you would like more information on our water main flushing schedule.

## QUESTIONS?

For more information about this report or if you have any questions about your drinking water, please contact Keith Hester, Water Division Superintendent, at (706) 883-2158. You may also email us at [utilities@lagrange.net](mailto:utilities@lagrange.net) or visit our Web site at [www.lagrange.net](http://www.lagrange.net).

## The Water Treatment Process

Creating clean drinking water consists of a series of precise steps overseen by certified water plant operators. First, source water is pumped from West Point Lake into a holding pond. Water then flows by gravity to a mixing basin where aluminum sulfate and complex polymers are added. These chemicals cause particles in the water to join together into larger particles called “floc” that settle to the bottom of large basins for later removal. Chlorine and chlorine dioxide are added for disinfection, metal removal, and taste and odor control.

At this point, water is filtered through layers of fine coal and silicate sand to remove remaining particles. Turbidity and particle counts, measures of water clarity, are regularly monitored as water emerges from the filters. Chlorine is added a second time before the water is stored in underground holding tanks to allow time for further disinfection to occur. We carefully measure and limit the amount of chlorine used to prevent the formation of disinfection by-products.

Before water leaves the plant, sodium hydroxide is added to control pH and alkalinity, fluoride is added as required by law to prevent tooth decay, and a corrosion inhibitor is added to coat and protect our piping. Finally, finished water is pumped into the distribution system for use by your home or business.

## What Causes the Pink Stain on Bathroom Fixtures?

The reddish-pink color frequently noted in bathrooms on shower stalls, tubs, tile, toilets, sinks, toothbrush holders and on pets’ water bowls is caused by the growth of the bacterium *Serratia marcescens*. *Serratia* is commonly isolated from soil, water, plants, insects, and vertebrates (including man). The bacteria can be introduced into the house through any of the above mentioned sources. The bathroom provides a perfect environment (moist and warm) for bacteria to thrive.

The best solution to this problem is to continually clean and dry the involved surfaces to keep them free from bacteria. Chlorine-based compounds work best, but keep in mind that abrasive cleaners may scratch fixtures, making them more susceptible to bacterial growth. Chlorine bleach can be used periodically to disinfect the toilet and help to eliminate the occurrence of the pink residue. Keeping bathtubs and sinks wiped down using a solution that contains chlorine will also help to minimize its occurrence.

*Serratia* will not survive in chlorinated drinking water.



### Is tap water cheaper than soda?

Yes! You can refill an 8 oz. glass of tap water approximately 15,000 times for the same cost as a six-pack of soda pop. And, water has no sugar or caffeine.

### How long can a person go without water?

Although a person can live without food for more than a month, a person can only live without water for approximately one week.

### When was drinking water first regulated?

The Safe Drinking Water Act (SDWA) of 1974 represents the first time that public drinking water supplies were protected on a federal (national) level in the U.S. Amendments were made to the SDWA in 1986 and 1996.

### Seventy-one percent of Earth is covered in water: how much is drinkable?

Oceans hold about 96.5 percent of all Earth’s water. Only three percent of the earth’s water can be used as drinking water. Seventy-five percent of the world’s fresh water is frozen in the polar ice caps.

## Benefits of Chlorination

Disinfection, a chemical process used to control disease-causing microorganisms by killing or inactivating them, is unquestionably the most important step in drinking water treatment. By far, the most common method of disinfection in North America is chlorination.

Before communities began routinely treating drinking water with chlorine, starting with Chicago and Jersey City in 1908, cholera, typhoid fever, dysentery, and hepatitis killed thousands of U.S. residents annually. Drinking water chlorination and filtration have helped to virtually eliminate these diseases in the United States. Significant strides in public health are directly linked to the adoption of drinking water chlorination. In fact, the filtration of drinking water plus the use of chlorine is probably the most significant public health advancement in human history.

## Sampling Results

During the past year, we have taken hundreds of water samples to determine the presence of any radioactive, biological, inorganic, volatile organic, or synthetic organic contaminants. The table below shows only those contaminants that were detected in the water. The state requires us to monitor for certain substances less than once per year because the concentrations of these substances do not change frequently. In these cases, the most recent sample data are included, along with the year in which the sample was taken.

### REGULATED SUBSTANCES

SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	MCL [MRDL]	MCLG [MRDLG]	AMOUNT DETECTED	RANGE LOW-HIGH	VIOLATION	TYPICAL SOURCE
Chlorine (ppm)	2015	[4]	[4]	1.27	1.04–1.50	No	Water additive used to control microbes
Chlorine Dioxide (ppb)	2015	[800]	[800]	240	60–500	No	Water additive used to control microbes
Chlorite (ppm)	2015	1	0.8	0.21	0.02–0.38	No	By-product of drinking water disinfection
Fluoride (ppm)	2015	4	4	0.72	0.45–1.03	No	Erosion of natural deposits; Water additive that promotes strong teeth; Discharge from fertilizer and aluminum factories
Haloacetic Acids [HAA] (ppb)	2015	60	NA	13.48	8.1–22.5	No	By-product of drinking water disinfection
Nitrate (ppm)	2015	10	10	1.5	NA	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
TTHMs [Total Trihalomethanes] (ppb)	2015	80	NA	35.13	17.1–67.6	No	By-product of drinking water disinfection
Total Organic Carbon (ppm)	2015	TT	NA	1.38	0.96–1.8	No	Naturally present in the environment
Turbidity <sup>1</sup> (NTU)	2015	TT	NA	0.27	0.03–0.27	No	Soil runoff
Turbidity (Lowest monthly percent of samples meeting limit)	2015	TT = 95% of samples < 0.3 NTU	NA	100	NA	No	Soil runoff

Tap water samples were collected for lead and copper analyses from sample sites throughout the community

SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	AL	MCLG	AMOUNT DETECTED (90TH% TILE)	SITES ABOVE AL/ TOTAL SITES	VIOLATION	TYPICAL SOURCE
Copper (ppm)	2015	1.3	1.3	0.18	0/15	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead (ppb)	2015	15	0	0	0/30	No	Corrosion of household plumbing systems; Erosion of natural deposits

### SECONDARY SUBSTANCES

SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	SMCL	MCLG	AMOUNT DETECTED	RANGE LOW-HIGH	VIOLATION	TYPICAL SOURCE
Iron (ppb)	2015	300	NA	10	10–20	No	Leaching from natural deposits; Industrial wastes
Manganese (ppb)	2015	50	NA	10	10–20	No	Leaching from natural deposits

### UNREGULATED SUBSTANCES

SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	AMOUNT DETECTED	RANGE LOW-HIGH	TYPICAL SOURCE
Bromodichloromethane (ppb)	2015	4.0	NA	By-product of drinking water disinfection
Chlorodibromomethane (ppb)	2015	2.9	NA	By-product of drinking water disinfection
Chloroform (ppb)	2015	2.7	NA	By-product of drinking water disinfection
Sodium (ppm)	NA	9.5	NA	Naturally occurring

<sup>1</sup> Turbidity is a measure of the cloudiness of the water. It is monitored because it is a good indicator of the effectiveness of the filtration system.

## Definitions

**AL (Action Level):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**LRAA (Locational Running Annual Average):** The average of sample analytical results for samples taken at a particular monitoring location during the previous four calendar quarters. Amount Detected values for TTHMs and HAAs are reported as LRAAs.

**MCL (Maximum Contaminant Level):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**MCLG (Maximum Contaminant Level Goal):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**MRDL (Maximum Residual Disinfectant Level):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**MRDLG (Maximum Residual Disinfectant Level Goal):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**NA:** Not applicable

**NTU (Nephelometric Turbidity Units):** Measurement of the clarity, or turbidity, of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

**ppb (parts per billion):** One part substance per billion parts water (or micrograms per liter).

**ppm (parts per million):** One part substance per million parts water (or milligrams per liter).

**SMCL (Secondary Maximum Contaminant Level):** SMCLs are established to regulate the aesthetics of drinking water like taste and odor.

**TT (Treatment Technique):** A required process intended to reduce the level of a contaminant in drinking water.